Replacement Parts for Adjustable Wall Faucets

CONTROL VALVE

2000-7500

SCREW

2000-8000

RED BUTTON AND

2000-8001

BLUE BUTTON

2000-2301

LEVER HANDLE

2000-3002

BIBB CAP

73657

DUCK GASKET

2000-5000

WASHER

2000-3406

LH CHECK STEM

2000-3407

RH CHECK STEM

2000-6000

SPRING

1000-7502

SCREW

73521

LUBE

CONTROL VALVE

2000-7500

SCREW

2000-8000

RED BUTTON

2000-8001

BLUE BUTTON

2000-2301

LEVER HANDLE

2000-3002 BIBB CAP

73657

DUCK GASKET

2000-5000

WASHER

3000-0010

LH SWIVEL STEM

3000-0011

RH SWIVEL STEM

SCREW

73521

LUBE

3200-2307

1/2" ECCENTRICS

2000-5003

SEAT WASHER

3200-2306

CONCENTRIC

FLANGES

3000-0000

RH SWIVEL STEM

REPAIR KIT

3000-0001

LH SWIVEL STEM REPAIR KIT

00

2200-5000

CONCENTRIC

GASKETS

2000-0004

RH CHECK STEM

REPAIR KIT

OR

2000-0005

LH CHECK STEM

REPAIR KIT



CVHB-RO-8AWLL Product Installation Guide

Since 1936, Fisher Manufacturing Company has manufactured heavy-duty, high quality plumbing products and hardware specialties for the food service industry. For three generations, the Fisher family has adhered to a strict dedication of and overall value. When you install Fisher products... you install the best. Our hardware is manufactured with the standardization of internal mechanisms. All chrome plating is triple plated copper, nickel and chrome for durability. Every piece of equipment we make is rigorously tested in both our modern in-house testing center and in actual field situations under extreme conditions. Every detail is thoroughly checked. Before we make our products available to you, they pass each and every test. You get proven performance. Guaranteed.



Limited One Year Warranty

Fisher Manufacturing Company warrants its products and parts thereof (except as noted below) against defects in materials or workmanship for a period of one year after the date of original purchase. During this period Fisher Manufacturing Company will replace a defective product or part without charge to you, provided that the entire product is delivered to Fisher Manufacturing Company. All transportation and insurance charges for shipping the product to and from Fisher Manufacturing Company must be borne by you. Charges for transportation and insurance may, at the option of Fisher Manufacturing Company, be refunded depending upon our investigation of the warranty claim. This warranty does not cover external finish (except at date of original purchase) or labor costs not specifically authorized by Fisher Manufacturing Company.

#2200 8"Backsplash Faucet with Swivel Stems
#2200-CV 8" Backsplash Faucet with Check Stems

A full and complete copy of our One Year limited

warranty is available upon request.

KEEP THIS MANUAL FOR FUTURE REFERENCE



2000-5003

SEAT WASHER





ANSI/A112.18.1M, ANSI/NSF 61.9

FISHER MANUFACTURING COMPANY - TOLL FREE: 800-421-6162 FAX: 800-832-8238



PART NO. 74669 www.fisher-mfg.com REV. A

www.fisher-mfg.com

Installation Instructions for Adjustable Wall Faucets

BE SURE TO CHECK WITH YOUR LOCAL DEPARTMENT HAVING JURISDICTION REGARDING BACKFLOW PREVENTION

Installation Notes:

- · Be sure to shut off water supply before beginning.
- Use pipe thread sealant such as PST on all threaded joints.
- · Check the packaging for missing items BEFORE beginning installation. If items are missing, contact your supplier.

Tools Required for Installation

- · Medium Sized Crescent Wrench
- · Pipe Thread Sealant



Package Contents

The box should contain the following:




Step 1.

Installation Instructions

After unpacking items and checking for missing components, insert and center the gasket into the female swivel inlets of the 8" control valve body. Loosely mount the eccentrics and flange onto the control valve body.

Step 2.

Mount control valve body to either a wall with a male supply nipples, or backsplash with nipples (not included). Be sure to use pipe thread sealant on the supply nipple threads. Adjust the eccentrics as needed in order to mount the control valve level. Once level, tighten the eccentrics



Installation Instructions Continued

Step 2

